Polling Place
Accessibility Survey

Polling Place Name/Location _____

What type of location?

School _____
Firehouse _____
Community Center _____
House of Worship _____
Other _____

	Yes	No
Are there designated accessible parking spaces?		
If yes, do they have visible signs (paint marking not required) that you can see while driving through the parking lot?		
Is there a parking space that is van accessible for lifts with a marked access aisle?		
Are the accessible parking spaces on the shortest route to the voting entrance?		
Is the parking lot and walkway surface solid, firm and slip resistant?		
Does the polling place provide an accessible drop off area close to the entrance?		
Is there a clear and level route of travel from the accessible parking spaces to the entrance with no stairs,curbs or other physical barriers?		
Is the path of travel from the parking area to the door clear for a person who is blind or has low vision (no wall mounted boxes, signs, plants etc.)		
Is a ramp needed (that is not currently present) at any point in order to gain access to the voting area?		
If there is an existing ramp, is it stable,not too steep, and have handrails on both sides?		
If there is a separate accessible entrance is the path to it clearly marked by a sign		
If there is a separate accessible entrance is the door unlocked?		

Polling Place Accessibility Survey

Does the entrance door (as well as any other doors voters must pass through) open at least 32 inches wide?		
Are door handles easily opened with one hand without grasping or pulling hard? *(this question can be answered NA if the doors are propped open)*		
Are the doors lightweight and easily opened with one hand? *{this question can by answered NA if the doors are propped open)*		
Has a barrier been placed in the entrance (to prop the door open) such as a trash can, planter or chair?		
Is the path from the entrance to the voting areas arranged in a way that makes it accessible to voters using a mobility device at least 36 inches wide with at least one area at least 48 inches wide which can be used for turnaround space?		
Has the voting line been arranged so it does not create a barrier that someone using a mobility device has to get around?		
Is the path from the entrance free from physical barriers including removable mats?		
Is there a place to rest while waiting in line?		
Is voting information, including curbside voting, posted at eye level for someone using a wheelchair?		
Is voting information posted in an area where everyone, including voters using a wheelchair, can see it without being blocked by a barrier such as a line of voters?		